# ALTERNATIVE POLYNOMIAL EQUATION APPROACH TO LQ DISCRETE-TIME FEEDBACK CONTROL

VÁCLAV SOUKUP

The usual solution of the single-input, single-output, LQ discrete-time feedback control through the polynomial equations is modified. The way starts with a general solution of the "implied" closed-loop equation the free polynomial of which is then optimized.

At the same time the conditions are derived under which the implied equation minimum solution represents the LQ optimal one. The conclusions are obtained to be more general if compared with the former results.

### 1. INTRODUCTION

The polynomial and polynomial matrix equation approach to LQ and LQG control problems is well-known. Fundamental results for general, multi-input, multioutput, discrete-time systems can be found in [4]. Many other contributions have been written in recent years to extend the problem solution for various types of the control structures and acting signals or reduce it under special assumptions, e.g., [1,2,3,5,6,7].

Although validity of the results presented below can be generalized, the simplest feedback structure of a single-input, single-output, deterministic control is considered according to Figure 1.




Fig. 1.

The output Y of a controlled process P should track a reference  $W_r$ , being affected simultaneously by a possible load disturbance V (referred to the output) and current nonzero conditions  $Y_0$  at the control start. C, E and U denote a controller, error and control signal, respectively. All the signals are assumed here to be described in the discrete-time fashions and P denotes the discrete-time model of a continuous-time process including the zero-order hold.

The relations

$$E = W - PU \quad \text{and} \quad U = CE \tag{1}$$

are obvious, where

$$W = W_r - V - Y_0 \tag{2}$$

is a (generalized) reference as the single input.

Hereafter, polynomials and sequences in d (one step delay in the time domain or the inverse Z-transform complex variable in the complex frequency domain) as well as the usual symbols are used. Namely, deg  $a, a^+, a^-, a_* = a(d^{-1}), a^- = d^{\text{deg}a}a_*$ concerning a polynomial a, (a, b), b|a and  $b \sim a$  for two polynomials,  $F_*(d) = F(d^{-1})$ and  $\langle F \rangle = \phi_0$  for a sequence  $F = \cdots + \phi_{-1}d^{-1} + \phi_0 + \phi_1d + \cdots$ . Moreover the only  $a^c$ to emphasize a causal polynomial and the factorization  $a = a^+a^0a^=$  are introduced, where all zeros  $d_i$  of  $a^+(d), a^0(d)$  and  $a^=(d)$  have the property  $|d_i| > 1, |d_i| = 1$  and  $|d_i| < 1$ , respectively.

The paper is organized into several parts. The standard way to solve the LQ discrete-time feedback control generally via the coupled polynomial equations is described briefly in Section 2. Then Section 3 deals with the other, alternative approach of the solution which starts with the "implied" equation. The second, related problem is treated in Section 4. The conditions are found under which the optimal LQ solution coincides with the minimum solution of the implied equation. The derived conclusions are more general if compared with the results reached by the other authors in [1] and [2].

#### 2. USUAL SOLUTION OF LQ DISCRETE-TIME FEEDBACK CONTROL

Let us consider the control structure shown in Figure 1, where

$$P = \frac{b}{a}; \quad a, b \quad \text{coprime}, \quad a = a^c, \quad b = d^\beta b^c, \quad \beta > 0, \tag{3}$$

$$W = W_r - V - Y_0 = \frac{f}{h}; \quad h, f \quad \text{coprime}, \quad h = h^c, \tag{4}$$

and the optimal controller C described by

$$C = \frac{m}{n}; \quad n^-, m^- \quad \text{coprime}, \tag{5}$$

is sought such that the performance index

$$\vartheta = \psi \langle EE_* \rangle + \phi \langle UU_* \rangle \tag{6}$$

reaches its minimum;  $\psi > 0$  and  $\phi > 0$  are the chosen weighting constants.

Using the description (3) and (4) a controlled process P as well as an input generator W are supposed to be minimal realizations of their input-output behaviour. In

200

this case the LQ control problem is generally solved by the minimum deg z solution m, n, z, deg  $z < \rho$ , of the coupled equations

$$d^{\rho}s_{*}m + ah_{a}z = d^{\rho}b_{*}\psi p \tag{7}$$

and

$$d^{\rho}s_*n - bh_a z = d^{\rho}a_*\phi p \tag{8}$$

where

$$\rho = \max(\deg a, \deg b), \quad h_a = \frac{h}{(a,h)} \quad \text{and} \quad a_h = \frac{a}{(a,h)}, \quad (9)$$

$$s = s^+$$
 follows from  $ss_* = \psi bb_* + \phi aa_*$ , (10)

and

$$p = p^+ p^0$$
 from  $pp_* = a_h a_{h*} ff_*$ . (11)

The problem becomes solvable if and only if  $h_a = h_a^+$  and  $p = p^+$  ( $p^0 = a_h^0 f^0 \sim 1$ ) and the optimal controller (5) is unique. The resulting error and corresponding control sequences are

$$E = \frac{a_h f n}{h_a s p}$$
 and  $U = \frac{a_h f m}{h_a s p}$ . (12)

The polynomial c determining the closed-loop finite poles follows from the simple arrangement of equations (7) and (8) into so-called "implied" equation

$$c = an + bm = sp. \tag{13}$$

Usually the single equation (7) instead of the couple (7) with (8) may be solved for minimum deg z, deg  $z < \rho$ , to obtain the optimal m, [3]. Such a simplified solution holds whenever deg  $(d^{\rho}s_{*}, ah_{a}) = \deg(d^{\rho}s_{*}, a^{-}) = 0$ . The remaining polynomial n follows from (13).

Notice that other current descriptions ([1, 2, 3, 4]) uses

$$P = \frac{B}{A}$$
 and  $W = \frac{F}{A}$  (14)

where the couples A, B and A, F are not necessarily coprime but  $(A, B, F) \sim 1$ . (Capital letters stand for polynomials.)

Comparing (14) with (3) and (4) yields

$$A = ah_a = ha_h, \quad B = bh_a \quad \text{and} \quad F = fa_h. \tag{15}$$

# 3. ALTERNATIVE SOLUTION OF LQ DISCRETE-TIME FEEDBACK CON-TROL

The other possible way to solve the LQ discrete-time, feedback control problem is presented in the following claim.

201

Claim 1. LQ discrete-time feedback control problem given by the relations (3) to (6) and (9) to (11) is solved by

$$m = m_p + at$$
 and  $n = n_p - bt$  (16)

where  $m_p$ ,  $n_p$  is any particular solution of the implied equation (13) and t belongs to the minimum deg z solution z, t, deg  $z < \rho$ , of the polynomial equation

$$d^{\rho}s_{*}t + h_{a}z = r, \tag{17}$$

where introducing

$$q = \psi b n_{p*} - \phi a m_{p*} \tag{18}$$

yields  $r = d^{\rho}q_*/s$  being always a polynomial.

The problem is solvable if and only if  $h_a = h_a^+$  and  $p = p^+$  and the solution is unique.

Proof. Suppose that polynomials m, n standing in (16) form just the optimal controller (5), i.e., they solve equations (7) and (8) with minimum deg z, deg  $z < \rho$ .

Substituting (16) into (7) and (8) we obtain

$$d^{\rho}s_{*}m_{p} + a(d^{\rho}s_{*}t + h_{a}z) = d^{\rho}b_{*}\psi p \tag{19}$$

and

$$d^{\rho}s_{*}n_{p} - b(d^{\rho}s_{*}t + h_{a}z) = d^{\rho}a_{*}\phi p.$$
(20)

If (19) multiplied by  $n_p$  and (20) by  $m_p$  are mutually subtracted we have

$$(an_p + bm_p)(d^{\rho}s_*t + h_a z) = pd^{\rho}(\psi b_* n_p - \phi a_* m_p) \quad \text{or} \quad sr = d^{\rho}q_*$$
(21)

when (17), (18) and the relation  $an_p + bm_p = sp$  have been used. Hence (17) has to be solved for minimum deg z, deg  $z < \rho$ . Seeing (12)  $h_a = h_a^+$  and  $p = p^+$  are found to be necessary as well as sufficient conditions of the problem solvability. In this case (17) is always solvable and the solution in unique.

# 4. OPTIMAL LQ FEEDBACK CONTROL SOLUTION VIA THE IMPLIED EQUATION ONLY

Using and analyzing the previous relations the sufficient conditions can be found under which the special particular solution of the single implied equation (13) is just the LQ optimal one. The following claim gives the resulting conclusions.

Claim 2. LQ discrete-time feedback control problem defined by relations (3) to (6) and (9) to (11) is solved uniquely by the minimum deg m solution m, n, deg  $m < \deg a$ , of the equation (13), if simultaneously

$$\deg h_a = 0 \tag{22}$$

and

$$\deg a + \beta > \deg p \,. \tag{23}$$

Alternative Polynomial Equation Approach to LQ Discrete-Time Feedback Control

**Proof.** Let us assume that  $m_p$ ,  $n_p$  in (16) is the minimum deg *m* solution of (13) which should coincide with the optimal LQ solution *m*, *n*. Then t = 0 in (16) as well as (17) such that  $h_a z = r$ . Generally (but not necessarily always)  $h_a$  does not divide *r* and therefore condition (22) or  $h_a = 1$  must be supposed to ensure the polynomial fashion of *z*; then z = r.

Since optimal polynomial z with deg  $z < \rho$  is unique, the desired identity z = r follows simply from the degree relation

$$\deg z = \deg r < \rho \,. \tag{24}$$

Thus the conditions have to be found under which (24) is true.

Several preliminary relations are emphasized at first.

1. 
$$\deg(d^{\rho}s_{*}) = \deg(d^{\rho}a_{*}) = \rho$$
 and  $\deg(d^{\rho}b_{*}) = \rho - \beta.$  (25)

2. The following cases of the process model properties may be distinguished:

- i)  $\deg a > \deg b^c$ ; then  $\deg s = \deg a$  (26)
- ii)  $\deg a = \deg b^c$ ; then either  $\deg s = \deg a$  (27)
  - or  $\deg s < \deg a$  (28)
- iii)  $\deg a < \deg b^c$ ; then  $\deg s = \deg b^c$ . (29)

3. The degrees of minimum deg m solution  $m_p$ ,  $n_p$  of (13) are as follows:

$\deg m_p <$	$\deg a$	(30)

and either		
	$\deg n_p < \deg b$	(31)

if 
$$\deg a + \deg b > \deg s + \deg p \tag{32}$$

or 
$$\deg n_p < \deg s + \deg p - \deg a + 1 \tag{33}$$

$$\deg a + \deg b \le \deg s + \deg p \,. \tag{34}$$

Usual (generic) degrees are the upper limits in (30) and (31) or (33), i.e., deg  $m_p = \deg a - 1$  and deg  $n_p = \deg b - 1$  or deg  $n_p = \deg s + \deg p - \deg a$ .

Seeing (18) and (21) and applying (25) we can write

if

$$\deg r = \deg (d^{\rho}q_{*}) - \deg s \leq \max (\rho - \beta + \deg n_{p}, \rho + \deg m_{p}) - \deg s = \rho - \deg s + \max (\deg n_{p} - \beta, \deg m_{p}).$$
(35)

Provided (32) is valid the relation (35) obtains the form

 $\deg r < \rho - \deg s + \max \ (\deg b^c, \deg a).$ 

Hence obviously (24) is fulfilled if (26) or (27) or (29) is true. In the case (28) we express

$$abd^{\rho}q_{*} = d^{\rho}b_{*}\psi ban_{p} - d^{\rho}a_{*}\phi abm_{p}$$
  
=  $d^{\rho}b_{*}\psi ban_{p} - d^{\rho}s_{*}sbm_{p} + d^{\rho}b_{*}\psi bbm_{p}$   
=  $d^{\rho}b_{*}\psi bsp - d^{\rho}s_{*}sbm_{p} = sb(d^{\rho}b_{*}\psi p - d^{\rho}s_{*}m_{p}).$ 

(37)

(38)

$$ad^{\rho}q_{*} = s(d^{\rho}b_{*}\psi p - d^{\rho}s_{*}m_{p})$$

Then and

$$\deg r = \deg (d^{\rho}b_{*}\psi p - d^{\rho}s_{*}m_{p}) - \deg a$$
  

$$\leq \max (\rho - \beta + \deg p, \rho + \deg a - 1) - \deg a$$
  

$$= \rho + \deg p - \beta - \deg a, -1).$$

Hence the condition (23) must be valid to ensure (24). Since this condition is always satisfied in the previous cases too, it is sufficient for the whole case (32).

If (34) is true then (35) has the form

$$\deg r < \rho - \deg s + \max(\deg s + \deg p - \deg a + 1 - \beta, \deg a)$$
  
=  $\rho + \max(\deg p - \deg a + 1 - \beta, \deg a - \deg s).$ 

Hence deg  $r < \rho$  if (26) or (27) is valid and (23) is satisfied at the same time.

Investigating the remaining cases (28) and (29) we find that (23) would be true again. But the contradictory relation deg  $a + \beta \leq \deg p$  follows from (34). Moreover deg  $a - \deg s > 0$  breaks (23) too in the case (28). Therefore (23) can never be reached provided (28) or (29) along with (34) are valid.

Thus conditions (22) and (23) are verified to be the sufficient conditions for LQ optimality of the minimum deg m solution of the implied equation (13).

The condition (23)

- is always true if (26) or (27) or (29) along with (32) hold
- can be true if either (28) with (32) or (26) or (27) with (34) hold
- is never true if either (28) or (29) along with (34) are valid.

# 5. CONCLUSIONS

The derived sufficient conditions (22) and (23) may be compared with the former results presented by the other authors.

The first investigation of LQ optimality of the implied equation minimum solution was given for matrix equations of multivariable systems in [1]. Based on this work the SISO case results have been formulated in [2] or [3]. The respective conditions, although considered there in the stochastic framework, may be expressed for the deterministic approach in the form using starting description (14) as

- i) A and B coprime; (36)
- ii) F stable;
- iii) W = F/A proper (with respect to d).

If our assumptions and denotations are used these conditions obtain the form

i) deg  $h_a = 0;$ 

204

Alternative Polynomial Equation Approach to LQ Discrete-Time Feedback Control

- ii) stability of  $F = a_h f$  is always secured since F is replaced by p according to (11);
- iii)  $\deg a \ge \deg p$  or  $\deg a + 1 > \deg p$ .

Comparing these relations with the results of Claim 2 one can see the difference in condition (37) or (39) and (23). They only coincide if  $\beta = 1$ , i.e., for processes and systems without deadtime longer than the sampling time. For  $\beta > 1$ , when a process having deadtime longer than a sampling time is controlled, properness of Wis not necessary but (23). Therefore (23) represents the more general condition if compared with (37).

## 6. EXAMPLE

Let us solve the LQ control problem for  $\psi = 1$  and  $\phi = 0.75$ , if

$$P = \frac{b}{a} = \frac{d^2(1 - 0.5d)}{1 - 2d}, \qquad W = \frac{f}{h} = \frac{1 - 0.1d - 0.2d^2}{1 - 2d}.$$

At first we determine  $h_a = 1$ ,  $a_h = 0$ ,  $p = f^+ = f = 1 - 0.1d - 0.2d^2$ , s = -2 + d,  $\rho = 3$ ,  $\deg a = 1$ ,  $\deg h_a = 0$ ,  $\deg s = 1$ ,  $\deg p = 2$  and  $\beta = 2$ .

Although W is not proper the conditions of Claim 2 are satisfied and the minimum deg m solution of the implied equation

$$(1-2d) n + d^2(1-0.5d) m = (-2+d) (1-0.1d-0.2d^2)$$

is

$$m = -7.2$$
 and  $n = -2 - 2.8d + 1.9d^2$ 

which is just the optimal one.

Writing a general solution

$$m = -7.2 + (1 - 2d)t$$
 and  $n = -2 - 2.8d + 1.9d^2 - d^2(1 - 0.5d)t$ 

we can determine

$$q = 7.3 - 14.55d - 0.6d^2 + d^3$$
 and  $r = -0.5 + 0.05d + 7.3d^2$ .

The equation (17)

$$d^{2}(1-2d)t + z = -0.5 + 0.05d + 7.3d^{2}$$

is solved for minimum deg z by t = 0, z = r, deg  $z = \deg r < \rho$ .

Solving the problem by the usual couple (7) and (8)

$$d^{2}(1-2d) m + (1-2d) z = (-0.5+d) (1-0.1d-0.2d^{2})$$

 $\operatorname{and}$ 

$$d^{2}(1-2d) n - d^{2}(1-0.5d) z = 0.75d^{2}(-2+d) (1-0.1d-0.2d^{2})$$

yields the same results.

(Received December 5, 1994.)

205

(39)

 $\mathbf{R} \to \mathbf{F} \to \mathbf{R} \to \mathbf{N} \to \mathbf{C} \to \mathbf{S}$ 

- K. J. Hunt, M. Šebek and M. J. Grimble: Optimal multivariable LQG control using a single diophantine equation. Internat. J. Control 46 (1987), 4, 1445-1453.
- [2] K. J. Hunt: Stochastic Optimal Control Theory with Applications in Self Tuning Control. Springer Verlag, Berlin-Heidelberg 1989.
- [3] J. Ježek and K. J. Hunt: Coupled polynomial equations for LQ synthesis and an algorithm for solution. Internat. J. Control 58 (1993), 5, 1155-1167.
- [4] V. Kučera: Discrete Linear Control. Wiley, Chichester 1979.
- [5] V. Kučera and M. Šebek: A polynomial solution to regulation and tracking. Part I and II. Kybernetika 19 (1984), 3, 177-188 and 4, 257-282.
- [6] A. P. Roberts: Simpler polynomial solutions in control and filtering. IMA J. Math. Control Inform. 3 (1986), 311-321.
- [7] A. P. Roberts: Simpler polynomial solutions in stochastic feedback control. Internat. J. Control 45 (1987), 117-126.

Doc. Ing. Václav Soukup, CSc., Elektrotechnická fakulta ČVUT (Faculty of Electrical Engineering – Czech Technical University), Karlovo nám. 13, 12135 Praha 2. Czech Republic.