

# Kybernetika

VOLUME 45 (2009), NUMBER 1

The Journal of the Czech Society for  
Cybernetics and Information Sciences

Published by:

Institute of Information Theory and Automation of the AS CR

## Editorial Office:

Pod Vodárenskou věží 4, 182 08 Praha 8

### Editor-in-Chief:

Milan Mareš

### Managing Editors:

Lucie Fajfrová  
Karel Sladký

## Editorial Board:

Jiří Anděl, Sergej Čelikovský, Marie Demlová, Jan Flusser, Petr Hájek, Vladimír Havlena, Didier Henrion, Yiguang Hong, Zdeněk Hurák, Martin Janžura, Jan Ježek, George Klir, Ivan Kramosil, Tomáš Kroupa, Petr Lachout, Friedrich Liese, Jean-Jacques Loiseau, František Matúš, Radko Mesiar, Karol Mikula, Jiří Outrata, Jan Seidler, Karel Sladký, Jan Štecha, Olga Štěpánková, František Turnovec, Igor Vajda, Jiřina, Vojnarová, Milan Vlach, Miloslav Vošvrda, Pavel Zítek

*Kybernetika* is a bi-monthly international journal dedicated for rapid publication of high-quality, peer-reviewed research articles in fields covered by its title.

*Kybernetika* traditionally publishes research results in the fields of Control Sciences, Information Sciences, System Sciences, Statistical Decision Making, Applied Probability Theory, Random Processes, Fuzziness and Uncertainty Theories, Operations Research and Theoretical Computer Science, as well as in the topics closely related to the above fields.

The Journal has been monitored in the Science Citation Index since 1977 and it is abstracted/indexed in databases of Mathematical Reviews, Zentralblatt für Mathematik, Current Mathematical Publications, Current Contents ISI Engineering and Computing Technology.

---

*Kybernetika*. Volume 45 (2009)

ISSN 0023-5954, MK ČR E 4902.

Published bimonthly by the Institute of Information Theory and Automation of the Academy of Sciences of the Czech Republic, Pod Vodárenskou věží 4, 182 08 Praha 8. — Address of the Editor: P. O. Box 18, 182 08 Prague 8, e-mail: kybernetika@utia.cas.cz. — Printed by PV Press, Pod vrstevnicí 5, 140 00 Prague 4. — Orders and subscriptions should be placed with: MYRIS TRADE Ltd., P. O. Box 2, V Štíhlách 1311, 142 01 Prague 4, Czech Republic, e-mail: myris@myris.cz. — Sole agent for all “western” countries: Kubon & Sagner, P. O. Box 34 01 08, D-8 000 München 34, F.R.G.

Published in February 2009.

© Institute of Information Theory and Automation of the AS CR, Prague 2009.

## ROBUST DECENTRALIZED $H_2$ CONTROL OF MULTI-CHANNEL DESCRIPTOR SYSTEMS WITH NORM-BOUNDED PARAMETRIC UNCERTAINTIES

WEIHUA GUI, NING CHEN AND GUISHENG ZHAI

This paper considers a robust decentralized  $H_2$  control problem for multi-channel descriptor systems. The uncertainties are assumed to be time-invariant, norm-bounded, and exist in both the system and control input matrices. Our interest is focused on dynamic output feedback. A necessary and sufficient condition for an uncertain multi-channel descriptor system to be robustly stabilizable with a specified  $H_2$  norm is derived in terms of a strict nonlinear matrix inequality (NMI), that is, an NMI with no equality constraint. A two-stage homotopy method is proposed to solve the NMI iteratively. First, a decentralized controller for the nominal descriptor system is computed by imposing block-diagonal constraints on the coefficient matrices of the controller gradually. Then, the decentralized controller is modified, again gradually, to cope with the uncertainties. On each stage, groups of variables are fixed alternately at the iterations to reduce the NMI to linear matrix inequalities (LMIs). An example is given to show the efficiency of this method.

*Keywords:* decentralized control, descriptor systems, parametric uncertainty, homotopy method, nonlinear matrix inequality

*AMS Subject Classification:* 93A14, 93B51, 93B52, 93B40, 93C15

### 1. INTRODUCTION

Much attention has been paid to analysis and design of descriptor systems since such systems have extensive applications in various fields [2, 4, 7, 10, 11, 14]. Descriptor systems are also referred as singular systems, implicit systems, generalized state-space systems, differential-algebraic systems. A large number of results for descriptor systems have been obtained both in the areas of centralized control and decentralized control. For centralized control, Takaba et al. studied robust  $H_2$  performance of uncertain descriptor systems using LMI method [9]. Ikeda et al. considered  $H_2$  control problem for descriptor systems and derived a strict LMI condition which is necessary and sufficient for  $H_2$  control [5]. Yang et al. studied the design problem of standard  $H_2$  optimal controller for continuous-time descriptor systems. Parameterization of all stabilizing controller of the system is given using the method of linear fractional transformation [13]. Furthermore, by means of two  $H_2$

generalized algebraic Riccati equations and two generalized Lyapunov equations respectively, a design of standard  $H_2$  optimal controller and the calculation of optimal  $H_2$  norm are presented.

As for decentralized control, Ikeda et al. considered centralized design of decentralized stabilizing controllers for interconnected descriptor systems [6]. The design problem was formulated as a feasibility problem for a bilinear matrix inequality (BMI), and to solve the BMI, a homotopy method was proposed, where the interconnections between subsystems are increased gradually from zeros to the given magnitudes. Wo and Zou considered decentralized robust stabilization problem for large scale descriptor systems with parametric uncertainty [12].

Up to now, the robust output feedback control problem for multi-channel descriptor systems by LMI method still remains open. The model of multi-channel descriptor systems includes the model of interconnected descriptor systems. Therefore, the study of multi-channel descriptor systems has practical value. Zhai et al. studied decentralized  $H_2$  control problem for multi-channel descriptor systems and proposed strict LMI conditions for designing low order decentralized controller [16]. In that context, the uncertainties are not considered in the descriptor systems.

Based on the observation that there is very few existing result considering decentralized  $H_2$  controller design for multi-channel descriptor systems with parametric uncertainties, this paper considers a robust decentralized  $H_2$  control problem for multi-channel descriptor systems with parametric uncertainties. The uncertainties are assumed to be time-invariant, norm-bounded, and exist in both the system and control input matrices. Our interest is focused on dynamic output feedback. A necessary and sufficient condition for an uncertain multi-channel descriptor system to be robustly stabilizable with  $H_2$  norm, is developed in terms of a strict nonlinear matrix inequality (NMI), that is, an NMI with no equality constraint. Then, a two-stage homotopy method is proposed to solve the NMI iteratively. The idea of the two-stage homotopy method [3] has been proposed by Chen et al. in solving a sufficient condition for a robust decentralized  $H_\infty$  controller to exist for interconnected systems, where the dimensions of local controllers are the same as those of corresponding subsystems. Here, a decentralized controller for the nominal descriptor system is first computed by imposing block-diagonal constraints on the coefficient matrices gradually. Then, the decentralized controller is modified, again gradually, to cope with the uncertainties. On each stage, groups of variables are fixed alternately at the iterations to reduce the NMI to LMIs. A given example shows the efficiency of this method.

This paper is organized as follows. Section 2 is devoted to the formulation of the robust decentralized  $H_2$  control problem. Section 3 presents a necessary and sufficient condition for a robust decentralized  $H_2$  controller to exist. In Section 4, a two-stage solution algorithm for the condition is proposed using homotopy methods. An example is presented in Section 5, which demonstrates the usefulness of the proposed algorithm. Finally, Section 6 concludes the paper.

## 2. PROBLEM DESCRIPTION

We consider an  $N$ -channel descriptor system with uncertainties, which is described by

$$\begin{cases} E\dot{x} = (A + \delta A)x + B_1w + \sum_{i=1}^N (B_{2i} + \delta B_{2i})u_i \\ z = C_1x \\ y_i = C_{2i}x, \quad i = 1, 2, \dots, N \end{cases} \quad (1)$$

where  $x \in \mathbb{R}^n$  is the descriptor variable,  $w \in \mathbb{R}^q$  is the disturbance input,  $z \in \mathbb{R}^p$  is the controlled output, and  $u_i \in \mathbb{R}^{m_i}$  and  $y_i \in \mathbb{R}^{l_i}$  are the control input and the measured output of channel  $i$  ( $i = 1, 2, \dots$ ), respectively. The matrices  $E$  and  $A$  are square, and  $E$  may be singular with the rank  $r \leq n$ . The matrices  $B_1, B_{2i}, C_1$  and  $C_{2i}$  are constant and of suitable dimensions, and  $\delta A$  and  $\delta B_{2i}$  respectively denote uncertainties in the system and control input matrices. We suppose that the uncertainties are described as

$$[\delta A \quad \delta B_{21} \quad \dots \quad \delta B_{2N}] = L\Delta [F_1 \quad F_{21} \quad \dots \quad F_{2N}] \quad (2)$$

where  $L, F_1, \dots, F_{2N}$  are known constant matrices, and  $\Delta$  is an unknown constant matrix satisfying

$$\Delta^T \Delta \leq I. \quad (3)$$

Furthermore, to ensure fitness of the  $H_2$  control problem, we assume that the system (1) satisfies the following condition [5]

$$\ker E \subset \ker C_1.$$

**Remark 1.** It is known that systems having direct transmission paths from  $w$  and  $u$  to  $z$  and  $y$  can be transformed to the form of (1) where no direct transmission appears explicitly, by augmenting the descriptor variable [7]. Therefore, the system (1) is a general representation of descriptor systems.

We adopt a decentralized output feedback controller described by

$$\begin{cases} \dot{\hat{x}}_i = \hat{A}_i \hat{x}_i + \hat{B}_i y_i \\ u_i = \hat{C}_i \hat{x}_i + \hat{D}_i y_i \end{cases}, \quad i = 1, 2, \dots, N \quad (4)$$

where  $\hat{x}_i \in \mathbb{R}^{\hat{n}_i}$  is the state of the  $i$ th local controller and  $\hat{n}_i$  is a specified dimension. The matrices  $\hat{A}_i, \hat{B}_i, \hat{C}_i, \hat{D}_i, i = 1, 2, \dots, N$  are constant and to be determined.

To write the closed-loop system composed of the system (1) and the controller (4) in a compact form, we denote matrices in (1) and (2) as

$$\begin{cases} B_2 = [B_{21} \quad B_{22} \quad \dots \quad B_{2N}] \\ C_2 = [C_{21}^T \quad C_{22}^T \quad \dots \quad C_{2N}^T]^T \\ \delta B_2 = [\delta B_{21} \quad \delta B_{22} \quad \dots \quad \delta B_{2N}] \\ F_2 = [F_{21} \quad F_{22} \quad \dots \quad F_{2N}] \end{cases} \quad (5)$$

and define the state and matrices of (4) as

$$\begin{cases} \hat{x} = [\hat{x}_1^T & \hat{x}_2^T & \cdots & \hat{x}_N^T]^T \\ \hat{A}_D = \text{diag}\{\hat{A}_1, \hat{A}_2, \dots, \hat{A}_N\}, \hat{B}_D = \text{diag}\{\hat{B}_1, \hat{B}_2, \dots, \hat{B}_N\} \\ \hat{C}_D = \text{diag}\{\hat{C}_1, \hat{C}_2, \dots, \hat{C}_N\}, \hat{D}_D = \text{diag}\{\hat{D}_1, \hat{D}_2, \dots, \hat{D}_N\} \end{cases} \quad (6)$$

$$G_D = \begin{bmatrix} \hat{A}_D & \hat{B}_D \\ \hat{C}_D & \hat{D}_D \end{bmatrix}. \quad (7)$$

Furthermore, we introduce the notations

$$\begin{aligned} \tilde{x} &= [x^T \quad \hat{x}^T]^T, \quad \tilde{E} = \begin{bmatrix} E & 0_{n \times \hat{n}} \\ 0_{\hat{n} \times n} & I_{\hat{n}} \end{bmatrix}, \quad \tilde{A} = \begin{bmatrix} A & 0_{n \times \hat{n}} \\ 0_{\hat{n} \times n} & 0_{\hat{n} \times \hat{n}} \end{bmatrix}, \\ \tilde{B}_1 &= \begin{bmatrix} B_1 \\ 0_{\hat{n} \times q} \end{bmatrix}, \quad \tilde{B}_2 = \begin{bmatrix} 0_{n \times \hat{n}} & B_2 \\ I_{\hat{n}} & 0_{\hat{n} \times m} \end{bmatrix}, \quad \tilde{C}_1 = [C_1 \quad 0_{p \times \hat{n}}], \\ \tilde{C}_2 &= \begin{bmatrix} 0_{\hat{n} \times n} & I_{\hat{n}} \\ C_2 & 0_{l \times \hat{n}} \end{bmatrix}, \quad \delta \tilde{A} = \begin{bmatrix} \delta A & 0_{n \times \hat{n}} \\ 0_{\hat{n} \times n} & 0_{\hat{n} \times \hat{n}} \end{bmatrix}, \quad \delta \tilde{B}_2 = \begin{bmatrix} 0_{n \times \hat{n}} & \delta B_2 \\ 0_{\hat{n} \times \hat{n}} & 0_{\hat{n} \times m} \end{bmatrix}, \\ \tilde{L} &= \begin{bmatrix} L \\ 0_{\hat{n} \times l} \end{bmatrix}, \quad \tilde{F}_1 = [F_1 \quad 0_{l \times \hat{n}}], \quad \tilde{F}_2 = [F_2 \quad 0_{l \times \hat{n}}] \end{aligned} \quad (8)$$

where  $\hat{n} = \sum_{i=1}^N \hat{n}_i$ ,  $m = \sum_{i=1}^N m_i$ ,  $l = \sum_{i=1}^N l_i$ , so that the closed-loop system is written as

$$\begin{aligned} \tilde{E} \dot{\tilde{x}} &= [\tilde{A} + \delta \tilde{A} + (\tilde{B}_2 + \delta \tilde{B}_2) G_D \tilde{C}_2] \tilde{x} + \tilde{B}_1 w \\ &= [\tilde{A} + \tilde{L} \Delta \tilde{F}_1 + (\tilde{B}_2 + \tilde{L} \Delta \tilde{F}_2) G_D \tilde{C}_2] \tilde{x} + \tilde{B}_1 w \\ z &= \tilde{C}_1 \tilde{x}. \end{aligned} \quad (9)$$

We denote the transfer function from the disturbance input  $w$  to the controlled output  $z$  of the closed-loop system by  $T_{zw}(s)$ . We say that the uncertain descriptor system (1) is robustly stabilizable with  $H_2$  norm  $\gamma$  if there exists a controller (4) so that the closed-loop system is stable and  $\|T_{zw}(s)\|_2 < \gamma$  holds for any  $\Delta$  satisfying (3), where  $\gamma$  is a specified positive number. The control problem of this paper is to design a decentralized controller (4) realizing such a closed-loop system.

### 3. EXISTENCE CONDITION FOR DECENTRALIZED $H_2$ CONTROLLER

To obtain the condition under which the closed-loop system (9) is stable with  $H_2$  norm  $\gamma$ , we employ the following lemmas. Let  $V, U \in \mathbb{R}^{n \times (n-r)}$  be matrices of full column ranks and composed of bases of Null  $E$  and Null  $E^T$ , respectively. We decompose  $E$  as  $E = E_L E_R^T$ , where  $E_L$  and  $E_R$  are of full column ranks.

**Lemma 1.** (Ikeda et al. [5]) Consider a linear descriptor system

$$\begin{cases} E \dot{x} = Ax + Bw \\ z = Cx \end{cases} \quad (10)$$

where  $x \in \mathbb{R}^n$  is the descriptor variable,  $w \in \mathbb{R}^q$  is the input,  $z \in \mathbb{R}^p$  is the output, and  $E, A, B, C$  are constant matrices of suitable dimensions. Then, for a given constant  $\gamma > 0$ , the system (10) is stable and satisfies

$$\|C(sE - A)^{-1}B\|_2 < \gamma \quad (11)$$

if and only if there exist a symmetric matrix  $P$  and a matrix  $S$  which satisfy the LMIs

$$\begin{aligned} (PE + USV^T)^T A + A^T(PE + USV^T) + C^T C &< 0 \\ \text{trace}[B^T P B] &< \gamma^2. \end{aligned} \quad (12)$$

**Lemma 2.** (Petersen [8]) Suppose that  $\Xi, L$ , and  $F$  are matrices of suitable dimensions and  $\Xi$  is symmetric. Then,

$$\Xi + L\Delta F + F^T \Delta^T L^T < 0 \quad (13)$$

holds for all  $\Delta$  satisfying  $\Delta^T \Delta \leq I$ , if and only if there exists a scalar  $\varepsilon > 0$  such that

$$\Xi + \varepsilon LL^T + \varepsilon^{-1} F^T F < 0. \quad (14)$$

From these lemmas, a necessary and sufficient condition for the existence of a robust decentralized  $H_2$  controller is derived as follows.

**Theorem 1.** For a given constant  $\gamma > 0$ , the uncertain descriptor system (1) is robustly stabilizable with  $H_2$  norm  $\gamma$  via a decentralized controller (4) composed of  $\hat{n}_i$ -dimensional local controllers, if and only if there exist a matrix  $G_D$  of (7), a symmetric matrix  $\tilde{P} \in \mathbb{R}^{(n+\hat{n}) \times (n+\hat{n})}$ , a matrix  $\tilde{S} \in \mathbb{R}^{(n-r) \times (n-r)}$ , and a scalar  $\varepsilon > 0$  such that

$$\begin{aligned} J(G_D, \tilde{P}, \tilde{S}, \varepsilon) &= \phi_1 + \phi_u < 0 \\ \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] &< \gamma^2 \end{aligned} \quad (15)$$

hold, where

$$\begin{aligned} \phi_1 &= (\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T)^T (\tilde{A} + \tilde{B}_2 G_D \tilde{C}_2) \\ &\quad + (\tilde{A} + \tilde{B}_2 G_D \tilde{C}_2)^T (\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T) + \tilde{C}_1^T \tilde{C}_1 \\ \phi_u &= \varepsilon (\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T) \tilde{L} \tilde{L}^T (\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T)^T \\ &\quad + \varepsilon^{-1} (\tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2)^T (\tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2) \\ \tilde{V} &= \begin{bmatrix} V \\ 0_{\hat{n} \times (n-r)} \end{bmatrix}, \quad \tilde{U} = \begin{bmatrix} U \\ 0_{\hat{n} \times (n-r)} \end{bmatrix}. \end{aligned} \quad (16)$$

*Proof.* From Lemma 1 for the system (9), we see that the uncertain multi-channel descriptor system is robustly stabilizable with the disturbance attenuation level  $\gamma$ ,

if and only if there exist a matrix  $G_D$  of (7), a symmetric matrix  $\tilde{P}$ , and a matrix  $\tilde{S}$  such that

$$\begin{aligned} & \phi_1 + [(\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T)\tilde{L}]\Delta[\tilde{F}_1 + \tilde{F}_2G_D\tilde{C}_2] \\ & + \{[(\tilde{P}\tilde{E} + \tilde{U}\tilde{S}\tilde{V}^T)\tilde{L}]\Delta[\tilde{F}_1 + \tilde{F}_2G_D\tilde{C}_2]\}^T < 0 \\ & \text{trace}[\tilde{B}_1^T\tilde{P}\tilde{B}_1] < \gamma^2 \end{aligned} \quad (17)$$

hold. Based on Lemma 2, inequalities (17) hold for any  $\Delta$  satisfying (3) if and only if there exist  $G_D, \tilde{P}, \tilde{S}$  and  $\varepsilon > 0$  such that (15) hold. This completes the proof.  $\square$

#### 4. COMPUTATION ALGORITHM

The existence condition (15) for a robust decentralized  $H_2$  controller is an NMI with the variables  $G_D, \tilde{P}, \tilde{S}$  and  $\varepsilon$ , which is generally very hard to solve. In order to overcome this difficulty, we adopt the idea of the homotopy method. For this purpose, we first decompose  $J(G_D, \tilde{P}, \tilde{S}, \varepsilon)$  of (15) into the nominal part  $J_0(G_D, \tilde{P}, \tilde{S})$  and the perturbation part  $J_u(G_D, \tilde{P}, \tilde{S}, \varepsilon)$  generated by the uncertainties, as

$$J(G_D, \tilde{P}, \tilde{S}, \varepsilon) = J_0(G_D, \tilde{P}, \tilde{S}) + J_u(G_D, \tilde{P}, \tilde{S}, \varepsilon) \quad (18)$$

where

$$J_0(G_D, \tilde{P}, \tilde{S}) = \phi_1 \quad (19)$$

and

$$J_u(G_D, \tilde{P}, \tilde{S}, \varepsilon) = \phi_u. \quad (20)$$

##### 4.1. A solution algorithm for nominal descriptor system

We propose a two-stage homotopy method. On the first stage, we consider only the nominal part. In this case, the NMI (15) is a BMI  $J_0(G_D, \tilde{P}, \tilde{S}) < 0$ ,  $\text{trace}[\tilde{B}_1^T\tilde{P}\tilde{B}_1] < \gamma^2$ . To solve this, we introduce a real number  $\lambda$  varying from 0 to 1 and define a matrix function as

$$H_0(G_D, \tilde{P}, \tilde{S}, \lambda) = J_0((1 - \lambda)G_F + \lambda G_D, \tilde{P}, \tilde{S}) \quad (21)$$

where

$$G_F = \begin{bmatrix} A_F & B_F \\ C_F & D_F \end{bmatrix} \quad (22)$$

and  $A_F, B_F, C_F, D_F$  are coefficient matrices of a centralized  $H_2$  controller for the performance  $\gamma$  with the same dimension as the decentralized one (4). The idea of the matrix function  $H_0(G_D, \tilde{P}, \tilde{S}, \lambda)$  of (21) is that we gradually impose block-diagonal constraints on the coefficient matrices of the controller. Then,

$$H_0(G_D, \tilde{P}, \tilde{S}, \lambda) = \begin{cases} J_0(G_F, \tilde{P}, \tilde{S}), & \lambda = 0 \\ J_0(G_D, \tilde{P}, \tilde{S}), & \lambda = 1 \end{cases} \quad (23)$$

and the problem of finding a solution to (15) is embedded in the parametrized family of problems

$$H_0(G_D, \tilde{P}, \tilde{S}, \lambda) < 0, \quad \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2, \quad \lambda \in [0, 1]. \quad (24)$$

We start computation of the solution to (24) with  $\lambda = 0$  where we need a centralized  $H_2$  controller as the initial value in the homotopy method for the decentralized controller. Here, we suggest using the design method [5] of an  $H_2$  controller for a descriptor system with an appropriate modification. That is, we first compute a centralized  $H_2$  controller in a descriptor form, and then convert it to a state equation. The dimension of the centralized controller obtained in the state space is  $r$ .

Following the discrete method [1], we let  $M$  be a positive integer and consider  $(M + 1)$  points  $\lambda_k = k/M$  ( $k = 0, 1, \dots, M$ ) in the interval  $[0, 1]$  to generate a family of problems

$$H_0(G_D, \tilde{P}, \tilde{S}, \lambda_k) < 0, \quad \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2. \quad (25)$$

If the problem at the  $k$ th point is feasible, we denote the obtained solution by  $(G_{Dk}, \tilde{P}_k, \tilde{S}_k)$ . Then, we compute a solution  $(G_{D,k+1}, \tilde{P}_{k+1}, \tilde{S}_{k+1})$  of  $H_0(G_D, \tilde{P}, \tilde{S}, \lambda_{k+1}) < 0, \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$  by solving it as an LMI with variables being fixed as  $\tilde{P} = \tilde{P}_k, \tilde{S} = \tilde{S}_k$  or  $G_D = G_{Dk}$ . If the family of problems  $H_0(G_D, \tilde{P}, \tilde{S}, \lambda_k) < 0, \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2, k = 1, 2, \dots, M$  are all feasible, a solution of the NMI (15) is obtained at  $k = M$  ( $\lambda = 1$ ). If it is not the case, that is, both  $H_0(G_D, \tilde{P}, \tilde{S}, \lambda_{k+1}) < 0, \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$  are infeasible for some  $k$ , we consider more points in the interval  $[\lambda_k, 1]$  by increasing  $M$ , and repeat the procedure from the solution  $(G_{Dk}, \tilde{P}_k, \tilde{S}_k)$  at  $\lambda = \lambda_k$ .

The above idea is summarized as a computation algorithm for a decentralized  $H_2$  output feedback controller.

*Step 1.* Initialize  $M$  to a certain positive integer, and set a certain upper bound  $M_{\max}$  for  $M$ . Set  $k = 0$ . Let  $G_{Dk} = \hat{G}_{D0}$  and  $\tilde{P}_k = \hat{P}_0, \tilde{S}_k = \hat{S}_0$  in accordance with the initial centralized controller.

*Step 2.* Set  $k := k+1$  and  $\lambda_k = k/M$ . Compute a solution  $G_D$  of  $H_0(G_D, \tilde{P}_{k-1}, \tilde{S}_{k-1}, \lambda_k) < 0$ . If it is not feasible, go to Step 3. If it is feasible, set  $G_{Dk} = G_D$ , and compute a solution  $(\tilde{P}, \tilde{S})$  of  $H_0(G_{Dk}, \tilde{P}, \tilde{S}, \lambda_k) < 0$ . Then, set  $\tilde{P}_k = \tilde{P}, \tilde{S}_k = \tilde{S}$  and go to Step 5.

*Step 3.* Compute a solution  $(\tilde{P}, \tilde{S})$  of  $H_0(G_{D,k-1}, \tilde{P}, \tilde{S}, \lambda_k) < 0, \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$ . If it is not feasible, go to Step 4. If it is feasible, set  $\tilde{P}_k = \tilde{P}, \tilde{S}_k = \tilde{S}$ , and compute a solution  $G_D$  of  $H_0(G_D, \tilde{P}_k, \tilde{S}_k, \lambda_k) < 0$ . Then, set  $G_{Dk} = G_D$ , and go to Step 5.

*Step 4.* Set  $M := 2M$  under the constraint  $M \leq M_{\max}$ , set  $\tilde{P}_{2(k-1)} = \tilde{P}_{k-1}, \tilde{S}_{2(k-1)} = \tilde{S}_{k-1}, \tilde{G}_{D,2(k-1)} = \tilde{G}_{D,k-1}, k := 2(k-1)$  and go to Step 2. If we cannot increase  $M$  any more, we conclude that this algorithm does not converge.

*Step 5.* If  $k < M$  go to Step 2. If  $k = M$  the obtained  $(G_{DM}, \tilde{P}_M, \tilde{S}_M)$  is a solution of (24).



If the dimension  $\hat{n}$  of the decentralized controller (4) is equal to  $r$ , we can apply the computation method of Zhai et al. [15], which has been proposed for state-space models. If we obtain a solution at  $\lambda = 1$ , it gives us a decentralized  $H_2$  controller for the nominal system. If the dimension  $\hat{n}$  of the controller (4) is less than  $r$ , we can also use the technique of Zhai et al. [15]. More precisely, we define  $\hat{G}_D$  by augmenting the matrix  $G_D$  as

$$\hat{G}_D = \left[ \begin{array}{cc|c} \hat{A}_D & 0_{\hat{n} \times (r-\hat{n})} & \hat{B}_D \\ * & -I_{r-\hat{n}} & ** \\ \hline \hat{C}_D & 0_{m \times (r-\hat{n})} & \hat{D}_D \end{array} \right] \quad (26)$$

where the notations  $*$ ,  $**$  are any submatrices, and  $\hat{A}_D, \hat{B}_D, \hat{C}_D, \hat{D}_D$  were defined in (6). We note that the  $r$ -dimensional controller defined by  $\hat{G}_D$  of (26) is equivalent to the  $\hat{n}$ -dimensional decentralized controller defined by  $G_D$  of (7) if we extract their controllable and observable parts. Then, replacing with  $\hat{G}_D$  in the matrix function (21), we solve the feasibility problem of (24) by the homotopy method.

If the dimension  $\hat{n}$  of the controller (4) is greater than  $r$ , we define  $\hat{G}_F$  by augmenting the matrix  $G_F$  as

$$\hat{G}_F = \left[ \begin{array}{cc|c} A_F & 0_{\hat{n} \times (\hat{n}-r)} & B_F \\ * & -I_{\hat{n}-r} & ** \\ \hline C_F & 0_{m \times (\hat{n}-r)} & D_F \end{array} \right] \quad (27)$$

where  $A_F, B_F, C_F$  and  $D_F$  were defined in (22). We note that the  $\hat{n}$ -dimensional centralized controller defined by  $\hat{G}_F$  of (27) is equivalent to the  $r$ -dimensional centralized controller defined by  $G_F$  of (22) if we extract their controllable and observable parts. In this case, replacing  $G_F$  with  $\hat{G}_F$  in (21), we solve the feasibility problem of (24) by the homotopy method.

**Remark 2.** In this paper, we consider local controllers of specified dimensions. Then, we may not stabilize the system even if the sum of dimensions of the local controllers is equal to that of the system. For this reason, we deal with the case  $\hat{n} > r$  as well as  $\hat{n} \leq r$ . Furthermore, by considering higher dimensional local controllers, we may achieve a better disturbance attenuation level.

**Remark 3.** Though  $-I$  was set at the (2,2)-block of  $\hat{G}_D$  in (26) and  $\hat{G}_F$  in (27) for simplicity, it can be any stable matrix and variable.

#### 4.2. A solution algorithm for uncertain descriptor system

Now, we suppose that a solution  $(G_D, \tilde{P}, \tilde{S})$  of (24) at  $\lambda = 1$  on the first stage has been obtained, which we denote by  $(\hat{G}_{D0}, \hat{P}_0, \hat{S}_0)$ . That is, we have a solution of the decentralized  $H_2$  control problem for the case of no uncertainty. Then, we proceed to the second stage, where we take into account uncertainties in the multi-channel descriptor system (1). In order to compute a solution of NMI (15), we again employ

a homotopy method in a different way. We introduce a real number  $\tilde{\lambda} \in [0, 1]$  and define the matrix function

$$H_1(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}) = J_0(G_D, \tilde{P}, \tilde{S}) + \tilde{\lambda} J_u(G_D, \tilde{P}, \tilde{S}, \varepsilon). \quad (28)$$

Then,

$$H_1(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}) = \begin{cases} J_0(G_D, \tilde{P}, \tilde{S}), \tilde{\lambda} = 0 \\ J(G_D, \tilde{P}, \tilde{S}, \varepsilon), \tilde{\lambda} = 1 \end{cases} \quad (29)$$

and the problem of finding a solution to (15) is embedded in the parametrized family of problems

$$H_1(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}) < 0, \quad \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2, \quad \tilde{\lambda} \in [0, 1]. \quad (30)$$

We note that the solution to (30) with  $\tilde{\lambda} = 0$  has been already obtained as  $(\hat{G}_{D0}, \hat{P}_0, \hat{S}_0)$  on the first stage.

To solve the matrix inequalities (30), we apply the Schur complement and consider two equivalent matrix inequalities shown as

$$\begin{aligned} H_{11}(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}) &= \begin{bmatrix} \phi_1 + \phi_{u1} & (\tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2)^T \\ \tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2 & -\varepsilon \tilde{\lambda}^{-1} I \end{bmatrix} < 0 \\ \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] &< \gamma^2 \\ \phi_{u1} &= \varepsilon \tilde{\lambda} (\tilde{P} \tilde{E} + \tilde{U} \tilde{S} \tilde{V}^T) \tilde{L} \tilde{L}^T (\tilde{P} \tilde{E} + \tilde{U} \tilde{S} \tilde{V}^T)^T \end{aligned} \quad (31)$$

and

$$\begin{aligned} H_{12}(G_D, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}) &= \begin{bmatrix} \phi_1 + \phi_{u2} & (\tilde{P} \tilde{E} + \tilde{U} \tilde{S} \tilde{V}^T) \tilde{L} \\ \tilde{L}^T (\tilde{P} \tilde{E} + \tilde{U} \tilde{S} \tilde{V}^T)^T & -\varepsilon^{-1} \tilde{\lambda}^{-1} I \end{bmatrix} < 0 \\ \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] &< \gamma^2 \\ \phi_{u2} &= \varepsilon^{-1} \tilde{\lambda} (\tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2)^T (\tilde{F}_1 + \tilde{F}_2 G_D \tilde{C}_2). \end{aligned} \quad (32)$$

We note that if we fix  $\tilde{P}$  and  $\tilde{S}$ , then  $H_{11}(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}) < 0$  becomes an LMI with respect to  $G_D$  and  $\varepsilon$ . On the other hand, if we fix  $G_D$ , then  $H_{12}(G_D, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}) < 0$  is an LMI in  $\tilde{P}, \tilde{S}$  and  $\varepsilon^{-1}$ . We use this property in the homotopy method of the second stage.

Following the discrete method [1], we let  $M$  be a positive integer and consider  $(M+1)$  points  $\tilde{\lambda}_k = k/M$  ( $k = 0, 1, \dots, M$ ) in the interval  $[0, 1]$  to generate a family of problems

$$H_1(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}_k) < 0, \quad \text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2. \quad (33)$$

If the problem at the  $k$ th point is feasible, we denote the obtained solution by  $(G_{Dk}, \tilde{P}_k, \tilde{S}_k)$ . Then, we compute a solution  $(G_{D,k+1}, \tilde{P}_{k+1}, \tilde{S}_{k+1})$  of  $H_{11}(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}_{k+1}) < 0$  or  $H_{12}(G_D, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}_{k+1}) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$  by solving it as an

LMI with variables being fixed as  $\tilde{P} = \tilde{P}_k, \tilde{S} = \tilde{S}_k$  or  $G_D = G_{Dk}$ . If the family of problems  $H_1(G_D, \tilde{P}, \tilde{S}, \varepsilon, \tilde{\lambda}_k) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$ ,  $k = 1, 2, \dots, M$  are all feasible, a solution of the NMI (15) is obtained at  $k = M$  ( $\tilde{\lambda} = 1$ ). If it is not the case, that is, both  $H_{11}(G_D, \tilde{P}_k, \tilde{S}_k, \varepsilon, \tilde{\lambda}_{k+1}) < 0$  and  $H_{12}(G_D, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}_{k+1}) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$  are infeasible for some  $k$ , we consider more points in the interval  $[\tilde{\lambda}_k, 1]$  by increasing  $M$ , and repeat the procedure from the solution  $(G_{Dk}, \tilde{P}_k, \tilde{S}_k)$  at  $\lambda = \tilde{\lambda}_k$ .

We formulate this idea of the second stage as an algorithm for computing a robust decentralized  $H_2$  controller.

*Step 1.* Initialize  $M$  to a certain positive integer, and set a certain upper bound  $M_{\max}$  for  $M$ . Set  $k = 0$ . Let  $G_{Dk} = \hat{G}_{D0}$  and  $\tilde{P}_k = \hat{P}_0, \tilde{S}_k = \hat{S}_0$  using the solution of the first stage.

*Step 2.* Set  $k := k+1$  and  $\tilde{\lambda}_k = k/M$ . Compute a solution  $(G_D, \varepsilon)$  of  $H_{11}(G_D, \tilde{P}_{k-1}, \tilde{S}_{k-1}, \varepsilon, \tilde{\lambda}_k) < 0$ . If it is not feasible, go to Step 3. If it is feasible, set  $G_{Dk} = G_D$  and compute a solution  $(\tilde{P}, \tilde{S}, \varepsilon^{-1})$  of  $H_{12}(G_{Dk}, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}_k) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$ . Then, set  $\tilde{P}_k = \tilde{P}, \tilde{S}_k = \tilde{S}$  and go to Step 5.

*Step 3.* Compute a solution  $(\tilde{P}, \tilde{S}, \varepsilon^{-1})$  of  $H_{12}(G_{D,k-1}, \tilde{P}, \tilde{S}, \varepsilon^{-1}, \tilde{\lambda}_k) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$ . If it is not feasible, go to Step 4. If it is feasible, set  $\tilde{P}_k = \tilde{P}, \tilde{S}_k = \tilde{S}$ , and compute a solution  $(G_D, \varepsilon)$  of  $H_{11}(G_D, \tilde{P}_k, \tilde{S}_k, \varepsilon, \tilde{\lambda}_k) < 0$ . Then, set  $G_{Dk} = G_D$ , and go to Step 5.

*Step 4.* Set  $M := 2M$  under the constraint  $M \leq M_{\max}$ , set  $\tilde{P}_{2(k-1)} = \tilde{P}_{k-1}, \tilde{S}_{2(k-1)} = \tilde{S}_{k-1}, \tilde{G}_{D,2(k-1)} = \tilde{G}_{D,k-1}, k := 2(k-1)$  and go to Step 2. If we cannot increase  $M$  any more, we conclude that this algorithm does not converge.

*Step 5.* If  $k < M$  go to Step 2. If  $k = M$  the obtained  $(G_{DM}, \tilde{P}_M, \tilde{S}_M, \varepsilon)$  is a solution of the NMI (15).

**Remark 4.** The convergence of the algorithm depends on the choice of the initial controllers, and a possible improvement is to consider random generation of the initial controllers since the subcontroller's size is small and can be parametrized.

**Remark 5.** When it is necessary, we can try to obtain a tight  $H_2$  norm  $\gamma$  by considering the generalized eigenvalue problem (EVP): "minimize  $\gamma^2$ , s. t. (24) or (30), respectively".

## 5. AN EXAMPLE

We present an example to demonstrate the efficiency of the proposed design method. We deal with a two-channel descriptor system, where the coefficient matrices of the nominal descriptor system are

$$\begin{aligned}
E &= \begin{bmatrix} 1 & 1 & 0 & 0 \\ 1 & -1 & 1 & 0 \\ 2 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \end{bmatrix}, \quad A = \begin{bmatrix} 0 & 0.6 & -1 & 0 \\ -4 & 0 & 0.8 & 0 \\ 0 & 0 & 1.5 & -1 \\ -1 & 1 & 0 & 0 \end{bmatrix}, \\
B_1 &= \begin{bmatrix} 1 \\ 0 \\ 0.5 \\ 0 \end{bmatrix}, \quad B_{21} = \begin{bmatrix} 1 \\ 0 \\ 1 \\ 0 \end{bmatrix}, \quad B_{22} = \begin{bmatrix} 0 \\ 1 \\ 0 \\ 1 \end{bmatrix}, \\
C_1 &= [ 1 \ 0 \ 0 \ 1 ], \quad C_{21} = [ -2 \ 3 \ -2 \ 1 ], \\
C_{22} &= [ 2 \ -1 \ 1 \ 0 ].
\end{aligned}$$

and the uncertainties are defined by

$$\begin{aligned}
L &= [ -0.2 \ 0.3 \ 0.1 \ 0.3 ]^T, \quad F_1 = [ 0.5 \ 0.1 \ 0.6 \ -0.2 ], \\
F_2 &= [ 0.6 \ 0.5 ].
\end{aligned}$$

Here, we consider the case  $r < \hat{n}$  and set the disturbance attenuation level to be achieved as 3. We design a decentralized  $H_2$  controller composed of two local controllers (4) whose dimensions are  $\hat{n}_1 = 2$  and  $\hat{n}_2 = 2$ . We note that the total dimension of the local controller is  $\hat{n} = \hat{n}_1 + \hat{n}_2 = 4$ , which is higher than the dimension  $r = 3$  of the controlled system.

To compute an initial value for the homotopy method of the first stage, we use the design method [5] of an  $H_2$  controller for a descriptor system with an appropriate modification as stated above. Then, we obtain a centralized controller in the state equation with the coefficient matrices

$$G_F = \left[ \begin{array}{ccc|cc} -5.2 & 2.45 & -0.87 & 0.35 & 0.97 \\ 4.45 & -7.19 & -2.00 & 1.6 & 0.08 \\ 3.74 & -1.82 & -1.31 & -0.19 & 0.69 \\ \hline -2.53 & 0.08 & -0.79 & 0.24 & -0.61 \\ 3.12 & -1.51 & -1.05 & -0.49 & 1.25 \end{array} \right].$$

We compute the solution of  $r$ -dimensional centralized  $H_2$  controller and augment it as  $\hat{G}_F$  of (27), that is

$$\hat{G}_F = \left[ \begin{array}{cccc|cc} -5.2 & 2.45 & -0.87 & 0 & 0.35 & 0.97 \\ 4.45 & -7.19 & -2.00 & 0 & 1.6 & 0.08 \\ 3.74 & -1.82 & -1.31 & 0 & -0.19 & 0.69 \\ 1 & 1 & 1 & -1 & 1 & 1 \\ \hline -2.53 & 0.08 & -0.79 & 0 & 0.24 & -0.61 \\ 3.12 & -1.51 & -1.05 & 0 & -0.49 & 1.25 \end{array} \right].$$

An initial solution  $(\tilde{P}_0, \tilde{S}_0)$  for  $H_0(G_D, \tilde{P}, \tilde{S}, \lambda) < 0, \text{trace}[B_1^T \tilde{P} B_1] < \gamma^2$  is computed by replacing  $\hat{G}_D$  with this  $G_F$  in  $J_0(\hat{G}_D \tilde{P}, \tilde{S}) < 0, \text{trace}[B_1^T \tilde{P} B_1] < \gamma^2$  as

$$\hat{P}_0 = \begin{bmatrix} 11.45 & 0.45 & 0.12 & -10.29 & -3.52 & -1.34 & -2.36 & 3.25 \\ 0.45 & 20.2 & 15.5 & -8.26 & 5.02 & 6.09 & -4.00 & 5.23 \\ 0.12 & 15.5 & 1.01 & 18.17 & 1.41 & 1.19 & -0.80 & -5.85 \\ -10.29 & -8.26 & 18.17 & 21.84 & -0.18 & -0.94 & -5.86 & -0.73 \\ -3.52 & 5.02 & 1.41 & -0.18 & 33.39 & -2.46 & 4.2 & -0.02 \\ -1.34 & 6.09 & 1.19 & -0.94 & -2.46 & 17.81 & 2.57 & -2.43 \\ -2.36 & -4.00 & -0.8 & -5.86 & 4.20 & 2.57 & 33.62 & -0.81 \\ 3.25 & 5.23 & -5.85 & -0.73 & -0.02 & -2.43 & -0.81 & 7.23 \end{bmatrix}$$

$$\tilde{S}_0 = -8.29$$

Then, for the nominal descriptor system, we design a decentralized  $H_2$  controller composed of two local controllers (4) of the dimensions  $\hat{n}_1 = 2$  and  $\hat{n}_2 = 2$ . Augmenting  $G_D$  as  $\hat{G}_D$  of (26), we obtain the coefficient matrices of a decentralized  $H_2$  controller by using the homotopy method with  $M = 16$  as

$$\hat{G}_{D0} = \left[ \begin{array}{cccc|cc} -7.68 & 14.49 & 0 & 0 & -3.8 & 0 \\ 3.50 & -11.91 & 0 & 0 & 3.57 & 0 \\ 0 & 0 & -23.95 & -7.61 & 0 & 2.76 \\ 0 & 0 & -10.6 & -6.70 & 0 & -3.12 \\ \hline -8.33 & 14.60 & 0 & 0 & -3.74 & 0 \\ 0 & 0 & -0.74 & 0.40 & 0 & 2.43 \end{array} \right]$$

and  $(\hat{P}_0, \hat{S}_0)$  by computing  $(\tilde{P}, \tilde{S}) < 0$  of  $J_0(G_D, \tilde{P}, \tilde{S}) < 0$ ,  $\text{trace}[\tilde{B}_1^T \tilde{P} \tilde{B}_1] < \gamma^2$  with  $G_D = \hat{G}_{D0}$  as

$$\hat{P}_0 = \begin{bmatrix} 3.46 & -5.28 & -0.10 & -13.19 & -3.00 & -0.19 & -0.46 & 3.17 \\ -5.28 & 8.60 & 16.04 & -5.67 & -1.72 & 9.51 & -1.06 & 3.22 \\ -0.10 & 16.04 & 7.47 & 14.62 & -6.01 & 0.92 & 0.56 & -3.71 \\ -13.19 & -5.67 & 14.62 & 21.08 & -0.09 & 0.35 & -3.98 & 7.66 \\ -3.00 & -1.72 & -6.01 & -0.09 & 20.37 & 9.57 & 0.64 & -0.97 \\ -0.19 & 9.51 & 0.92 & 0.35 & 9.57 & 17.16 & 1.37 & -3.34 \\ -0.46 & -1.06 & 0.56 & -3.98 & 0.64 & 1.37 & 6.40 & -2.83 \\ 3.17 & 3.22 & -3.71 & 7.66 & -0.97 & -3.34 & -2.83 & 10.68 \end{bmatrix}$$

$$\hat{S}_0 = -6.19.$$

On the second stage, we compute a robust decentralized  $H_2$  controller for the uncertain system using the algorithm proposed in Section 4. With  $M = 8$ , we obtain the coefficient matrices

$$\hat{G}_D = \left[ \begin{array}{cccc|cc} -4.61 & 1.89 & 0 & 0 & 0 & 0 \\ 0.22 & -2.18 & 0 & 0 & 0.70 & 0 \\ 0 & 0 & -25.16 & -9.03 & 0 & 1.73 \\ 0 & 0 & -9.16 & -5.96 & 0 & -3.79 \\ \hline -5.25 & 1.23 & 0 & 0 & 0.16 & 0 \\ 0 & 0 & -0.48 & 0.63 & 0 & 2.69 \end{array} \right].$$

## 6. CONCLUSION

This paper considered a robust decentralized  $H_2$  control problem for uncertain multi-channel systems. Based on a version of the strict bounded real lemma for descriptor systems, an NMI condition with no equality constraint was derived for a robust decentralized  $H_2$  controller to exist, which achieved a specified  $H_2$  norm. A two-stage homotopy method was proposed to solve the NMI iteratively. The method started with the solution to the centralized  $H_2$  control problem. The first homotopy stage considered decentralized controller with no uncertainty, and the second homotopy stage considered the presence of uncertainty. The proposed method allowed for controllers which have dimension either higher or lower than that of the centralized  $H_2$  controller. An example was given to illustrate the proposed method.

## ACKNOWLEDGEMENT

The authors would like to thank Professor Masao Ikeda with Osaka University for valuable discussions. This research has been supported in part by National Natural Science Foundation of China (60634020), in part by Hunan Provincial Natural Science Foundation of China (07JJ6138), in part by Specialized Research Fund for the Doctoral Program of Higher Education (20050533028), and in part by Postdoctoral Science Foundation of China (20060390883).

(Received March 13, 2008.)

## REFERENCES

---

- [1] J.H. Alva: The feasibility of continuation methods for nonlinear equations. *SIAM J. Numer. Anal.* *11* (1974), 1, 102–120.
- [2] T.N. Chang and E.J. Davison: Decentralized control of descriptor systems. *IEEE Trans. Automat. Control* *46* (2001), 1589–1595.
- [3] N. Chen, M. Ikeda, and W. Gui: Robust decentralized  $H_\infty$  control of interconnected systems: A design method using homotopy. In: *Preprints 10th IFAC/IFORS/IMACS/IFIP Symposium on Large Scale Systems: Theory and Applications*, Osaka 2004, pp. 330–336.
- [4] L. Dai: *Singular Control Systems*. Springer-Verlag, Berlin 1989.
- [5] M. Ikeda, T.W. Lee, and E. Uezato: A strict LMI condition for  $H_2$  control of descriptor systems. In: *Proc. 39th IEEE Conference on Decision and Control 2000*, pp. 601–604.
- [6] M. Ikeda, G. Zhai, and E. Uezato: Centralized design of decentralized stabilizing controllers for large-scale descriptor systems. *DCDIS Journal, Series B: Algorithms and Applications* *11* (2004), 509–520.
- [7] I. Masubuchi, Y. Kamitane, A. Ohara, and N. Suda:  $H_\infty$  control for descriptor systems: A matrix inequalities approach. *Automatica* *33* (1997), 669–673.
- [8] I.R. Petersen: A stabilization algorithm for a class of uncertain linear systems. *Systems Control Lett.* *8* (1987), 351–357.
- [9] K. Takaba:  $H_2$  output feedback control for descriptor systems. *Automatica* *34* (1998), 7, 841–850.

- [10] D. Wang and P. Bao: Robust impulse of uncertain singular systems by decentralized output feedback. *IEEE Trans. Automat. Control* *45* (2000), 500–505.
- [11] D. Wang and C.B. Soh: On regularizing singular systems by decentralized output feedback. *IEEE Trans. Automat. Control* *44* (1999), 148–152.
- [12] S.L. Wo and Y. Zou: Decentralized robust stabilization for singular large scale systems with parameter uncertainty. *Control and Decision* *19* (2004), 8, 931–934 (in Chinese).
- [13] H.S. Yang, Q.L. Zhang, and C.M. Shang:  $H_2$  optimal control for descriptor systems. *Acta Automat. Sinica* *28* (2002), 6, 920–926 (in Chinese).
- [14] R. Yu and D. Wang. (2003). On impulsive modes of linear singular systems subject to decentralized output feedback. *IEEE Trans. Automat. Control* *48* (2003), 1804–1809.
- [15] G. Zhai, M. Ikeda, and Y. Fujisaki: Decentralized  $H_\infty$  controller design: A matrix inequality approach using a homotopy method. *Automatica* *37* (2001), 4, 565–573.
- [16] G. Zhai, M. Yoshida, J. Imae, and T. Kobayashi: Decentralized  $H_2$  controller design for descriptor systems: An LMI approach. *Nonlinear Dynamics and Systems Theory* *6* (2006), 1, 98–108.

*Weihua Gui and Ning Chen, School of Information Science and Engineering, Central South University, Changsha, Hunan 410083. China.*

*e-mails: gwh@mail.csu.edu.cn, ningchen@mail.csu.edu.cn*

*Guisheng Zhai, Department of Mechanical Engineering, Osaka Prefecture University, Sakai, Osaka 599-8531. Japan.*

*e-mail: zhai@me.osakafu-u.ac.jp*